



Thermostat Cross Reference

SS (Single Stage), HP (Heat Pump), MS (Multi-Stage)

RESIDENTIAL or COMMERCIAL	SS, HP or MS#	Programmable	Number Of Days	Changeover	Application	Totaline "Gold"	Totaline "Signature"	Totaline "Star"	
RESIDENTIAL	Single Stage	Non-Programmable		Manual	1H		P374-0100	P474-0220	
				Manual	1C		P374-0000	P474-0220	
		Programmable	1-Day	Manual	1H and 1C		P374-0200		
				Auto	1H and 1C	P274-0100		P474-0100	
			1-Day	Auto	1H and 1C		P374-1000	P474-1010	
			1-Day	Manual	1H or 1C			P474-1020	
			5 + 2 Day	Auto	1H and 1C			P474-1050	
			7-Day	Auto	1H and 1C	P274-1100	P374-1100		
		Programmable	7-Day	Auto	1H and 1C		P374-1100FM		
			Flushmount Programmable	7-Day	Auto	1H and 1C			P474-1100RF
	Heat Pump	Non-Programmable		Manual	2H and 1C		P374-0300		
				Auto	2H and 1C	P274-0200		P474-0100	
		Programmable	1-Day	Auto	2H and 1C		P374-1000	P474-1010	
			5 + 2 Day	Auto	2H and 2C			P474-1050	
		Programmable	7-Day	Auto	2H and 1C	P274-1200	P374-1100		
			7-Day	Auto	2H and 2C		P374-1100FM		
		Flushmount Programmable	7-Day	Auto	2H and 2C			P474-1100RF	
		Wireless			Auto	2H and 2C			P474-0100
						3H and 2C	P274-0300		
		Programmable	5 + 2 Day	Auto	2H and 2C			P474-1050	
	7-Day		Auto	2H and 2C		P374-1100			
	Multi-Stage	Programmable	7-Day	Auto	2H and 2C			P374-1100	
					3H and 2C	P274-1300			
		Flushmount Programmable	7-Day	Auto	2H and 2C		P374-1100FM		
		Wireless	7-Day	Auto	2H and 2C			P474-1100RF	
	Adv. HP/DF	Programmable	7-Day	Auto	2H and 2C			P374-1500	
Dual Fuel				3H and 2C			P374-1500		
Intellistat	Programmable	7-Day	Auto	2H and 2C			P374-1600		
				Humidity & Temp. Control					
	Non Programmable			Auto	2H and 2C			P374-2100	
					2H and 2C			P474-2050	
	Programmable	5 + 2 Day		Auto	2H and 2C			P474-2150	
					2H and 2C	P274-2100		P374-2200	
	Programmable	7-Day		Auto	3H and 2C	P274-2100		P374-2300	
					2H and 2C		P374-2200FM		
	COMMERCIAL	Flushmount Programmable	7-Day	Auto	2H and 2C			P374-2300FM	
					2H and 2C			P474-2300RF	
Wireless				Auto	2H and 2C			P374-2200LA	
					Light Activated			P374-2300LA	

Literature Number 570-533

www.totaline.com

Replacement Components Division • ©Carrier Corporation 8/98 Rev. C 9/02



Thermostat Cross Reference

Honeywell Model	Electronic or Mechanical	Type (SS, HP or MS)#	Program- ming	Stages (maximum)	Change- over	Totaline * "Gold"	Totaline "Signature"	Totaline "Star"
T822D	Mechanical	SS	No	1H	-	P274-0100	P374-0100	P474-0220
T834C	Mechanical	SS	No	1H or 1C	-	P274-0100	P374-0200	P474-0100
T8034C	Mechanical	SS	No	1H or 1C	-	P274-0100	P374-0200	P474-0100
T87F	Mechanical	SS	No	1H or 1C	-	P274-0100	P374-0200	P474-0100
T87F + Q539	Mechanical	SS	No	1H / 1C	Manual	P274-0100	P374-0200	P474-0100
Y8224A-1019	Mechanical	SS	1-day	1H / 1C	Manual	P274-1100	P374-1000	P474-1010
Y594R	Mechanical	HP	No	2H / 1C	Manual	P274-0200	P374-0300	P474-0100
Y594G	Mechanical	HP	No	2H / 1C	Auto	P274-0200	P374-1000	P474-0100
T874D + Q674	Mechanical	MS	No	2H / 2C	Manual	P274-0300	P374-1100, FM	P474-0100
T8400C, T8401C	Electronic	SS	No	1H / 1C	Manual	P274-0100	P374-0200	P474-0100
T8500D, T8501D, T8502D	Electronic	SS	No	1H / 1C	Auto	P274-0100	P374-1000	P474-0100
T8600D, T8601D, T8602D	Electronic	SS	7-day	1H / 1C	Auto	P274-1100	P374-1100, FM	P474-1050‡
T8700C	Electronic	SS	1-day	1H / 1C	Manual	P274-1100	P374-1000	P474-1010
T8411R	Electronic	HP	No	2H / 1C	Manual	P274-0200	P374-0300	P474-0100
T8511G	Electronic	HP	No	2H / 1C	Auto	P274-0200	P374-1000	P474-0100
T8611G	Electronic	HP	7-day	2H / 1C	Auto	P274-0200	P374-1100, FM	P474-1050‡
T8621C	Electronic	MS	7-day	2H / 1C	Auto	P274-1300	P374-1100, FM	P474-1050‡
T8624D	Electronic	MS	7-day	2H / 2C	Auto	P274-1300	P374-1100, FM	P474-1050‡
T7100D/Q7100A	Electronic	MS	No	2H / 2C	Auto	P274-2100	P374-2100	P474-2050
T7300D/Q7300A	Electronic	MS	7-day	2H / 2C	Auto	P274-2100	P374-2300FM, LA	P474-2150^**
T7300E/Q7300C	Electronic	HP	7-day	3H / 2C	Auto	P274-2100	P374-1500	P474-2150^**
White Rodgers Model	Electronic or Mechanical	Type (SS, HP or MS)#	Program- ming	Stages (maximum)	Change- over	Totaline * "Gold"	Totaline "Signature"	Totaline "Star"
1C20	Mechanical	SS	No	1H	-	P274-0100	P374-0100	P474-0220
1F30	Mechanical	SS	No	1H	-	P274-0100	P374-0100	P474-0220
1E36/1F36	Mechanical	SS	No	1H or 1C	-	P274-0100	P374-0200	P474-0100
1E56/1F56	Mechanical	SS	No	1H / 1C	Manual	P274-0100	P374-0200	P474-0100
1F72	Mechanical	SS	1-day	1H or 1C	-	P274-1100	P374-1000	P474-1010
1F72 + S25	Mechanical	SS	1-day	1H / 1C	Manual	P274-1100	P374-1000	P474-1010
1F58-058	Mechanical	HP	No	2H / 1C	Manual	P274-0200	P374-0300	P474-0100
1C70-24	Mechanical	HP	No	2H / 2C	Manual	P274-0200	P374-0300	P474-0100
1C70-51	Mechanical	MS	No	2H / 1C	Manual	P274-0300	P374-1000	P474-0100
1F86-54	Electronic	SS	No	1H / 1C	Manual	P274-0100	P374-0200	P474-0100
1F80-24	Electronic	SS	1-day	1H / 1C	Manual	P274-1100	P374-1000	P474 1010
1F80-51	Electronic	SS	5 + 2 day	1H / 1C	Manual	P274-1100	P374-1100	P474-1050
1F90-71	Electronic	SS	5 + 2 day	1H / 1C	Auto	P274-1100	P374-1100	P474-1050
1F97-71	Electronic	SS	7-day	1H / 1C	Auto	P274-1100	P374-1100	P474-1050‡
1F89-51	Electronic	HP	No	2H / 1C	Manual	P274-0200	P374-0300	P474-0100
1F59-11	Electronic	HP	No	2H / 1C	Manual	P274-0200	P374-0300	P474-0100
1F92-71	Electronic	HP	5 + 2 day	3H / 2C	Auto	P274-1200	P374-1500	P474-1050‡**
1F94-71	Electronic	HP	7-day	3H / 2C	Auto	P274-1200	P374-1500	P474-1050‡**
1F95-71	Electronic	MS	7-day	3H / 2C	Auto	P274-1300	P374-1500	P474-1050‡**

* Totaline Gold thermostats require a 5-->4 wire converter (P274-0410) for 4 wire applications (power stealing and battery)

** Totaline Signature and Star thermostats have maximum of 2 Heating stages

SS (Single Stage), HP (Heat Pump), MS (Multi-Stage)

‡ 5+2 Day Programming

^ 5+1+1 Day Programming